



## **CITY OF MANTECA - FIRE DEPARTMENT**

### **FIRE PREVENTION BUREAU**

1154 S. UNION ROAD • MANTECA, CA 95337

(209) 456-8340 • FAX (209) 923-8936

## **CELLULOSE NITRATE FILM PERMIT REQUIREMENTS**

---

**105.6.6** An operational permit is required to store, handle or use cellulose nitrate film in a Group A occupancy.

**306.1 Motion picture projection rooms.** Electric arc, xenon or other light source projection equipment which develops hazardous gases, dust or radiation and the projection of ribbon- type cellulose nitrate film, regardless of the light source used in projection, shall be operated within a motion picture projection room complying with Section 409 of the California Building Code.

**306.2 Cellulose nitrate film storage.** Storage of cellulose nitrate film shall be in accordance with NFPA 40.

**906 Fire Extinguishers.** Two approved fire extinguishers with an approved water or water solution extinguisher with a minimum 10-B:C rating shall be installed and maintained ready for use in projection rooms, in accordance with NFPA 40.

**310 Smoking.** Smoking and other sources of ignition shall be prohibited within projection rooms in which cellulose nitrate film is allowed. Conspicuous NO SMOKING signs shall be posted in the room.

**Projection Equipment.** Projection equipment or film which is in a hazardous condition shall not be used.

Additional requirements may apply.