



CITY OF MANTECA - FIRE DEPARTMENT

FIRE PREVENTION BUREAU

1154 S. UNION ROAD • MANTECA, CA 95337

(209) 456-8340 • FAX (209) 923-8936

LIQUID OR GAS-FUELED VEHICLES OR EQUIPMENT IN ASSEMBLY BUILDING OPERATIONAL PERMIT REQUIREMENTS

105.6.27 LIQUID OR GAS-FUELED VEHICLES OR EQUIPMENT IN ASSEMBLY BUILDINGS. An operational permit is required to display, operate or demonstrate liquid- or gas-fueled vehicles or equipment in assembly buildings.

314.2 Fixtures and displays. Fixtures and displays of goods for sale are arranged to maintain free, immediate and unobstructed access to exits.

314.3 Highly combustible goods. The displays of highly combustible goods, including but not limited to fireworks, flammable or combustible liquids, liquefied flammable gases, oxidizing materials, pyroxylin plastics and agricultural goods are located 5 feet or more from entrances to exits and exterior exit doors.

314.4 Vehicles. Liquids-or-gas fueled vehicles, boats or other motor craft shall not be located indoors except as follows:

1. Batteries are disconnected.
2. Fuel in fuel tanks does not exceed one-quarter tank or 5 gallons (whichever is least).
3. Fuel tanks and fill opening are closed and sealed to prevent tampering
4. Vehicles, boats or other motor craft equipment are not fueled or defueled within the building.

Additional requirements may apply.